

Main stop valves for residential sprinklers systems in Class 9c buildings

QFES believe that where a booster connection is installed for an AS 2118.4 residential sprinkler system, protecting a Class 9c, aged care building, the main stop valve should be fitted with a monitoring device which is permanently connected via a direct data link, or other approved monitoring system, to a fire station or fire station dispatch centre.