

## Natural ventilation systems

QFR does not support the use of translucent sheets, installed as a means of providing permanent openings at roof level, in a natural smoke venting system but does support the use of ridge vents as an acceptable means of providing permanent openings at roof level.

Openable roller doors are not supported as a means of providing permanent or readily openable low-level openings for make-up air. QFR considers permanently open ventilation grilles or slots in roller doors, or fixed open grilles in walls to be a suitable means of providing make-up air for a natural or mechanical smoke venting system.